Table 3.2:
Elevator Shaft Inspection
Results by Elevator Car

FLOOR	CAR 1																	
	NORTH				EAST					SOUTH				WEST				
Panel	n1	n2	n3	n4	e1	e2	e3	e4	e5	s1	s2	s3	s4	w1	w2	w3	w4	w5
PH																		
24																		
23																		
22																		
21																		
20																		
19																		
18																		
17																		
16																		
15																		
14																		
M 13																		
M 12	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
11	c	c	c	c	c	c	c	c	c	N	N	N	N	c	c	c	c	c
10	c	c	c	c	1	c	c	c	c	N	N	N	N	c	c	c	c	c
9	c	c	c	c	c	c	c	c	c	N	N	N	N	c	c	c	c	c
8	c	c	c	c	c	c	c	c	c	N	N	N	N	c	c	c	c	c
7	c	c	c	c	c	c	c	c	c	N	N	N	N	c	c	c	c	c
6	c	c	c	c	c	c	c	c	c	N	N	N	N	c	c	c	c	c
5	c	c	c	c	c	<w	<w	c	c	N	N	N	N	c	c	c	c	c
4	c	w	w	c	c	c	c	c	c	N	N	N	N	c	c	w	c	c
3	c	<w	<w	c	c	c	c	c	c	N	N	N	N	w	w	c	c	c
2	c	c	c	c	c	c	c	c	c	N	N	N	N	w	w	w	c	c
1 upper	c	c	c	c	w	w	w	w	c	N	N	N	N	w	w	c	w	c
1 lower	c	c	c	c	c	c	c	c	c	N	N	N	N	c	c	c	c	c

Key:	
c	Clear
w	Water Staining
2	Visible Mold Growth (in square feet)
N	No Wall
o	Oil Staining
	Building Mechanical Level

CONFIDENTIAL

Table 3.2:
Elevator Shaft Inspection
Results by Elevator Car

FLOOR	CAR 2																	
	NORTH				EAST					SOUTH				WEST				
Panel	n1	n2	n3	n4	e1	e2	e3	e4	e5	s1	s2	s3	s4	w1	w2	w3	w4	w5
PH																		
24																		
23																		
22																		
21																		
20																		
19																		
18																		
17																		
16																		
15																		
14																		
M 13																		
M 12	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
11	N	N	N	N	c	w	w	w	w	w	c	c	w	c	c	c	c	c
10	N	N	N	N	>w	c	c	w	w	w	c	>w	>w	c	c	c	c	c
9	N	N	N	N	w	w	w	w	w	w	w	>w	>w	c	c	c	c	c
8	N	N	N	N	c	w	w	w	w	w	c	>w	>w	c	c	c	c	c
7	N	N	N	N	c	c	w	w	<w	<w	c	>w	>w	c	c	<w	c	c
6	N	N	N	N	c	c	c	c	c	c	w	w	w	<w	c	c	c	c
5	N	N	N	N	c	c	c	c	w	w	c	c	c	c	c	c	c	c
4	N	N	N	N	c	c	c	c	w	w	w	w	w	w	w	c	c	c
3	N	N	N	N	c	c	w	w	w	w	o	w	c	w	w	c	c	c
2	N	N	N	N	c	c	c	c	c	c	c	c	w	w	w	w	c	c
1 upper	N	N	N	N	c	c	c	c	c	c	c	c	c	w	c	c	w	c
1 lower	N	N	N	N	c	c	c	c	c	c	c	c	c	w	w	c	c	c

Key:	
c	Clear
w	Water Staining
2	Visible Mold Growth (in square feet)
N	No Wall
o	Oil Staining
	Building Mechanical Level

CONFIDENTIAL

Table 3.2:
Elevator Shaft Inspection
Results by Elevator Car

FLOOR	CAR 3																					
	NORTH					EAST						SOUTH					WEST					
Panel	n1	n2	n3	n4	n5	e1	e2	e3	e4	e5	e6	s1	s2	s3	s4	s5	w1	w2	w3	w4	w5	w6
PH																						
24																						
23																						
22																						
21																						
20																						
19																						
18																						
17																						
16																						
15																						
14																						
M 13																						
M 12	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
11	N	N	N	N	N	c	c	N	N	c	c	c	c	c	c	c	N	N	N	N	N	N
10	N	N	N	N	N	c	c	N	N	w	w	c	c	c	c	c	N	N	N	N	N	N
9	N	N	N	N	N	c	c	N	N	c	c	c	c	c	c	c	N	N	N	N	N	N
8	N	N	N	N	N	c	c	N	N	c	c	c	c	c	c	c	N	N	N	N	N	N
7	N	N	N	N	N	c	c	N	N	c	c	c	c	c	c	c	N	N	N	N	N	N
6	N	N	N	N	N	c	c	N	N	c	c	c	c	c	c	c	N	N	N	N	N	N
5	N	N	N	N	N	w	w	N	N	w	c	c	c	c	c	c	N	N	N	N	N	N
4	N	N	N	N	N	c	w	N	N	w	w	w	c	c	c	c	N	N	N	N	N	N
3	N	N	N	N	N	c	c	N	N	w	w	w	w	c	c	c	N	N	N	N	N	N
2	N	N	N	N	N	c	c	N	N	w	w	w	c	c	c	c	N	N	N	N	N	N
1 upper	N	N	N	N	N	w	w	N	N	c	w	c	c	c	c	c	N	N	N	N	N	N
1 lower	N	N	N	N	N	c	w	N	N	w	w	w	w	c	c	c	N	N	N	N	N	N

Key:	
c	Clear
w	Water Staining
2	Visible Mold Growth (in square feet)
N	No Wall
o	Oil Staining
	Building Mechanical Level

CONFIDENTIAL

Table 3.2:
Elevator Shaft Inspection
Results by Elevator Car

FLOOR	CAR 4																					
	NORTH					EAST						SOUTH					WEST					
Panel	n1	n2	n3	n4	n5	e1	e2	e3	e4	e5	e6	s1	s2	s3	s4	s5	w1	w2	w3	w4	w5	w6
PH																						
24																						
23																						
22																						
21																						
20																						
19																						
18																						
17																						
16																						
15																						
14																						
M 13																						
M 12	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
11	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
10	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
9	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
8	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
7	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
6	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
5	c	c	c	c	c	w	w	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
4	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
3	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
2	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
1 upper	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N
1 lower	c	c	c	c	c	c	c	N	N	c	c	N	N	N	N	N	N	N	N	N	N	N

Key:	
c	Clear
w	Water Staining
2	Visible Mold Growth (in square feet)
N	No Wall
o	Oil Staining
	Building Mechanical Level

CONFIDENTIAL

Table 3.2:
Elevator Shaft Inspection
Results by Elevator Car

FLOOR	CAR 5																				
	NORTH					EAST						SOUTH					WEST				
Panel	n1	n2	n3	n4	n5	e1	e2	e3	e4	e5	e6	s1	s2	s3	s4	s5	w1	w2	w3	w4	w5	w6
PH	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
24	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
23	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
22	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
21	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
20	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
19	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
18	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
17	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
16	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
15	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
14	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
M 13	w	w	w	w	c	c	c	c	c	c	c	N	N	N	N	N	w	w	w	w	w	c
M 12	c	c	c	c	c	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	c
11	c	c	c	c	c	N	N	N	N	N	N	N	N	N	N	N	w	w	c	w	c	c
10	w	w	c	c	c	N	N	N	N	N	N	N	N	N	N	N	w	w	w	w	1	c
9	c	c	c	c	c	N	N	N	N	N	N	N	N	N	N	N	w	w	c	c	c	c
8	w	w	c	c	c	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	w	c
7	c	c	c	c	c	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c
6	w	c	c	c	c	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	w	c
5	c	c	c	c	c	N	N	N	N	N	N	N	N	N	N	N	w	c	c	c	c	c
4	w	w	w	c	c	N	N	N	N	N	N	N	N	N	N	N	c	c	w	w	w	c
3	w	w	w	c	c	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	w	c
2	c	c	c	c	c	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c
1 upper	w	w	w	c	c	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c
1 lower	c	c	c	c	c	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c

Key:	
c	Clear
w	Water Staining
2	Visible Mold Growth (in square feet)
N	No Wall
o	Oil Staining
	Building Mechanical Level

CONFIDENTIAL

Table 3.2:
Elevator Shaft Inspection
Results by Elevator Car

FLOOR	CAR 6																					
	NORTH					EAST						SOUTH					WEST					
Panel	n1	n2	n3	n4	n5	e1	e2	e3	e4	e5	e6	s1	s2	s3	s4	s5	w1	w2	w3	w4	w5	w6
PH	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
24	N	N	N	N	N	w	w	w	w	w	c	w	w	w	w	c	c	c	c	c	c	c
23	N	N	N	N	N	w	c	c	c	c	c	c	c	w	c	c	c	c	c	c	c	c
22	N	N	N	N	N	c	c	c	c	c	c	c	c	w	w	c	c	c	c	c	c	c
21	N	N	N	N	N	c	c	c	c	c	c	c	c	1	1	c	c	c	c	c	c	c
20	N	N	N	N	N	c	c	c	c	c	c	c	c	1	1	1	c	c	c	c	c	c
19	N	N	N	N	N	c	c	c	c	c	c	c	c	1	1	c	c	c	c	c	c	c
18	N	N	N	N	N	c	c	c	c	c	c	w	c	1	1	c	w	c	c	c	c	c
17	N	N	N	N	N	c	c	c	c	w	c	c	1	c	c	c	c	c	c	c	c	c
16	N	N	N	N	N	c	c	c	c	c	c	c	1	1	1	c	c	c	c	c	c	c
15	N	N	N	N	N	c	c	c	w	w	c	c	1	1	c	c	c	c	c	c	c	c
14	N	N	N	N	N	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
M 13	N	N	N	N	N	c	c	c	c	c	c	w	w	w	w	c	w	w	w	w	w	c
M 12	N	N	N	N	N	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
11	N	N	N	N	N	N	N	N	N	N	N	w	w	c	c	c	c	c	c	w	c	c
10	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	w	w	c	c	w	c
9	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c	w	c	c	c	c
8	N	N	N	N	N	N	N	N	N	N	N	w	w	c	c	c	c	c	c	c	c	c
7	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c	c	c	c	c	c
6	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c	c	c	c	c	c
5	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c	w	c	w	w	c
4	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	w	w	c	w	c	c
3	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c	c	c	c	c	c
2	N	N	N	N	N	N	N	N	N	N	N	c	c	c	w	c	c	c	c	c	c	c
1 upper	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c	c	c	c	c	c
1 lower	N	N	N	N	N	N	N	N	N	N	N	c	c	c	c	c	c	c	c	c	c	c

Key:	
c	Clear
w	Water Staining
2	Visible Mold Growth (in square feet)
N	No Wall
o	Oil Staining
	Building Mechanical Level

CONFIDENTIAL

Table 3.2:
Elevator Shaft Inspection
Results by Elevator Car

FLOOR	CAR 7																					
	NORTH					EAST						SOUTH					WEST					
Panel	n1	n2	n3	n4	n5	e1	e2	e3	e4	e5	e6	s1	s2	s3	s4	s5	w1	w2	wz3	w4	w5	w6
PH	c	c	c	c	c	c	c	c	c	c	c	4	c	c	c	c	c	c	c	c	c	c
24	N	N	N	N	N	c	c	c	w	w	N	w	c	c	c	N	c	c	c	c	w	N
23	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	c	c	c	c	c	N
22	N	N	N	N	N	c	c	c	c	1	N	1	c	c	c	N	1	c	c	c	c	N
21	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	1	c	c	c	c	N
20	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	1	c	c	c	c	N
19	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	1	c	c	c	c	N
18	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	1	c	c	c	c	N
17	N	N	N	N	N	c	c	c	c	c	N	1	2	2	2	N	w	c	c	c	c	N
16	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	1	c	c	c	c	N
15	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	c	c	c	c	c	N
14	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	c	c	c	c	c	N
M 13	N	N	N	N	N	c	c	c	w	2	N	c	c	c	c	N	c	c	c	c	c	N
M 12	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	c	c	c	c	c	N
11	N	N	N	N	N	c	c	c	w	2	N	2	1	c	c	N	c	c	c	c	c	N
10	N	N	N	N	N	w	w	w	1	3	N	3	w	c	c	N	c	c	c	c	c	N
9	N	N	N	N	N	w	w	w	w	1	N	1	w	c	c	N	c	c	c	c	c	N
8	N	N	N	N	N	w	w	w	w	w	N	w	w	c	c	N	c	c	c	c	c	N
7	N	N	N	N	N	w	w	c	w	w	N	c	c	c	c	N	c	c	c	c	c	N
6	N	N	N	N	N	w	w	c	w	w	N	c	c	c	c	N	c	c	c	c	c	N
5	N	N	N	N	N	w	w	w	w	w	N	c	c	c	c	N	c	c	c	c	c	N
4	N	N	N	N	N	w	w	w	w	w	N	c	c	c	c	N	c	c	c	c	c	N
3	N	N	N	N	N	w	w	c	w	c	N	c	c	c	c	N	c	c	c	c	c	N
2	N	N	N	N	N	w	w	c	c	c	N	c	c	c	c	N	c	c	c	c	c	N
1 upper	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	c	c	c	c	c	N
1 lower	N	N	N	N	N	c	c	c	c	c	N	c	c	c	c	N	c	c	c	c	c	N

Key:	
c	Clear
w	Water Staining
2	Visible Mold Growth (in square feet)
N	No Wall
o	Oil Staining
	Building Mechanical Level

CONFIDENTIAL

Table 3.2:
Elevator Shaft Inspection
Results by Elevator Car

FLOOR	CAR 8																					
	NORTH					EAST						SOUTH					WEST					
Panel	n1	n2	n3	n4	n5	e1	e2	e3	e4	e5	e6	s1	s2	s3	s4	s5	w1	w2	wz3	w4	w5	w6
PH	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
24	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
23	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
22	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
21	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
20	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
19	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
18	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	1	c	w	c	c	N
17	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
16	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
15	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
14	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	w	c	c	w	N
M 13	N	N	N	N	N	2	2	c	c	c	c	N	N	N	N	N	c	w	c	c	c	N
M 12	N	N	N	N	N	2	2	c	c	c	c	N	N	N	N	N	c	w	c	c	c	N
11	N	N	N	N	N	w	w	c	w	w	c	N	N	N	N	N	c	c	c	c	c	N
10	N	N	N	N	N	c	c	c	w	w	c	N	N	N	N	N	c	c	c	c	c	N
9	N	N	N	N	N	c	c	c	w	c	c	N	N	N	N	N	c	c	c	c	c	N
8	N	N	N	N	N	c	c	w	w	w	c	N	N	N	N	N	c	c	c	c	c	N
7	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
6	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
5	N	N	N	N	N	w	c	c	c	w	c	N	N	N	N	N	c	c	c	c	c	N
4	N	N	N	N	N	c	w	w	w	w	c	N	N	N	N	N	c	c	c	c	c	N
3	N	N	N	N	N	c	c	c	w	w	c	N	N	N	N	N	c	c	c	c	c	N
2	N	N	N	N	N	c	c	c	w	w	c	N	N	N	N	N	c	c	c	c	c	N
1 upper	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N
1 lower	N	N	N	N	N	c	c	c	c	c	c	N	N	N	N	N	c	c	c	c	c	N

Key:	
c	Clear
w	Water Staining
2	Visible Mold Growth (in square feet)
N	No Wall
o	Oil Staining
	Building Mechanical Level

CONFIDENTIAL

Table 3.2:
Elevator Shaft Inspection
Results by Elevator Car

FLOOR	CAR 9																					
	NORTH					EAST						SOUTH					WEST					
Panel	n1	n2	n3	n4	n5	e1	e2	e3	e4	e5	e6	s1	s2	s3	s4	s5	w1	w2	w3	w4	w5	w6
PH	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
24	w	c	c	c	N	w	w	c	c	c	N	N	N	N	N	N	c	c	c	c	c	N
23	w	w	w	8	N	1	c	c	c	c	N	N	N	N	N	N	c	c	c	c	c	N
22	c	c	c	2	N	4	c	c	c	c	N	N	N	N	N	N	c	c	c	c	c	N
21	w	w	1	2	N	w	2	c	c	c	N	N	N	N	N	N	c	c	c	c	c	N
20	w	w	1	4	N	2	4	c	c	c	N	N	N	N	N	N	c	c	c	c	c	N
19	w	w	w	10	N	1	c	c	c	c	N	N	N	N	N	N	w	c	c	c	w	N
18	4	1	2	c	N	1	1	c	c	c	N	N	N	N	N	N	c	c	c	c	4	N
17	2	2	1	2	N	w	c	c	c	c	N	N	N	N	N	N	c	w	w	w	1	N
16	1	1	1	1	1	1	1	c	c	c	N	N	N	N	N	N	c	c	c	c	c	N
15	1	1	w	w	w	c	c	c	c	c	N	N	N	N	N	N	w	w	w	c	w	N
14	1	1	c	1	1	1	1	c	c	c	N	N	N	N	N	N	w	w	w	w	w	N
M 13	w	w	c	c	N	2	2	2	2	w	N	N	N	N	N	N	w	w	w	w	w	N
M 12	2	2	2	2	N	2	2	2	2	2	N	N	N	N	N	N	w	w	w	w	2	N
11	1	1	w	1	N	1	w	c	w	w	N	N	N	N	N	N	c	c	1	1	1	N
10	1	1	1	1	N	2	2	w	w	w	N	N	N	N	N	N	c	c	w	1	2	N
9	1	1	c	w	N	2	w	w	w	w	N	N	N	N	N	N	w	c	w	1	2	N
8	1	1	w	w	N	1	w	w	w	w	N	N	N	N	N	N	w	w	w	w	1	N
7	2	w	w	c	N	c	c	c	c	c	N	N	N	N	N	N	c	c	w	c	c	N
6	w	w	w	w	N	c	c	c	c	w	N	N	N	N	N	N	w	w	w	w	w	N
5	c	w	w	c	N	c	c	c	c	c	N	N	N	N	N	N	c	c	c	c	c	N
4	c	c	c	c	N	w	w	w	w	c	N	N	N	N	N	N	c	c	c	c	w	N
3	w	c	w	c	N	w	w	c	w	w	N	N	N	N	N	N	c	c	c	2	c	N
2	c	o	o	o	N	c	w	c	c	c	N	N	N	N	N	N	c	c	c	c	c	N
1 upper	c	c	w	w	N	c	c	c	c	c	N	N	N	N	N	N	c	c	c	c	c	N
1 lower	c	c	w	w	N	c	c	c	c	c	N	N	N	N	N	N	c	c	c	c	c	N

Key:	
c	Clear
w	Water Staining
2	Visible Mold Growth (in square feet)
N	No Wall
o	Oil Staining
	Building Mechanical Level

CONFIDENTIAL

Table 3.2:
Elevator Shaft Inspection
Results by Elevator Car

FLOOR	CAR 10																					
	NORTH						EAST					SOUTH						WEST				
Panel	n1	n2	n3	n4	n5	n6	e1	e2	e3	e4	e5	s1	s2	s3	s4	s5	s6	w1	w2	wz3	w4	w5
PH	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	w
24	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	?	?	c	c	c	c	c
23	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
22	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
21	c	c	c	c	c	c	c	c	c	c	c	c	<w	c	c	c	c	c	c	c	c	c
20	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
19	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
18	c	c	c	c	c	c	c	c	c	c	c	c	c	c	<w	c	c	c	c	c	c	c
17	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
16	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
15	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
14	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
M 13	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
M 12	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
11	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
10	c	c	c	c	c	c	c	c	c	c	c	c	w	w	w	c	c	c	c	c	c	c
9	c	c	c	c	c	c	c	c	c	c	c	c	w	c	w	c	c	c	c	c	c	c
8	c	c	c	c	c	c	c	c	c	c	c	c	c	c	w	c	c	c	c	c	c	c
7	<w	<w	c	c	c	c	w	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
6	c	c	1	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
5	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
4	c	c	c	c	c	<w	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
3	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c	c
2	w	w	w	w	w	w	c	c	c	c	c	w	c	w	c	c	c	w	w	w	w	w
1 upper	c	c	c	c	c	c	c	c	c	c	c	c	c	w	c	c	c	c	c	c	c	c
1 lower	c	c	c	c	c	c	c	c	c	w	w	c	c	w	c	c	c	c	c	c	c	c

Key:	
c	Clear
w	Water Staining
2	Visible Mold Growth (in square feet)
N	No Wall
o	Oil Staining
	Building Mechanical Level

CONFIDENTIAL