



HYGIENETECH

Hygiene Technologies International, Inc.

3625 Del Amo Boulevard, Suite 180
Torrance, California 90503-1643
(310) 370-8370
(310) 370-7026 FAX
www.hygienetech.com

June 23, 2009

State of California
Board of Equalization
450 N Street
Sacramento, California 94279

Document No. 20903001.4

Attention: David Gau

Regarding: Limited Fungal Growth Exposure Assessment Survey
Elevator Lobby Areas

Dear Mr. Gau:

On March 30, 2009, industrial hygienists with Hygiene Technologies International, Inc. (HygieneTech) conducted a limited fungal growth exposure assessment survey involving ten randomly selected elevator lobby areas located within the State of California Board of Equalization (BOE) building. This survey is one in a series of routine air quality assessments to monitor the indoor air quality of the building elevator lobby areas in regards to airborne fungal spores. The survey findings, along with the analytical data, conclusions, and recommendations appear below.

On the survey date, air samples were collected for total (viable and nonviable) fungi analyses using a Zefon brand Bio-Pump™ equipped with Allergenco-D™ cassettes. All such samples were subsequently analyzed for fungi (including yeasts, molds, rusts, smuts, and mushrooms) by trained and experienced microbiologists at a laboratory accredited by the American Industrial Hygiene Association (AIHA) and that successfully participates in the AIHA Environmental Microbiology Proficiency Analytical Testing (EMPAT) Program. The airborne fungi assessment analytical data with supporting and background information appear in the enclosed table.

As presented in Table 20903001-1010, the airborne spore count data recorded showed mostly common fungal spore types outdoors such as *Alternaria*, ascospores, basidiospores, *Chaetomium*, *Cladosporium*, colorless spores typical of *Penicillium* and *Aspergillus* species, *Oidium*, rusts, smuts, *Torula*, *Ulocladium*, and/or unidentified mitosporic fungi with *Cladosporium* predominating in both samples collected. In the indoor areas tested, the data showed low airborne concentrations of mostly common fungal spores that included one or more of the following: ascospores, basidiospores, *Cladosporium*, colorless spores typical of *Penicillium* and *Aspergillus* species, *Epicoccum*, *Pithomyces*, rust, smuts, *Stemphylium*, *Torula*, and/or unidentified mitosporic fungi. The distribution of fungal spore types detected in the surveyed areas was consistent with those found outdoors, and the overall data within the tested areas were well below the overall data recorded outdoors. These data are considered unremarkable and are not believed to pose a health risk beyond that posed by the outdoor environment where exposures to airborne fungi are expected.



Be advised that the data provided in this report only represent limited fungal growth exposure potentials that existed at the time the survey was performed and at the precise sample locations indicated, the latter of which were selected based on the available background information provided. Note that fungal growth and exposure potentials may change due to changes in environmental conditions (such as those caused by water intrusion), use of mechanical systems, or other factors. Also be advised that additional fungal growth may exist at one or more locations in the structure that were not specifically assessed during the survey.

If you have any comments or questions regarding the information contained in this correspondence, please feel free to contact our offices directly at (310) 370-8370.

Sincerely,

HYGIENE TECHNOLOGIES INTERNATIONAL, INC.

A handwritten signature in black ink, appearing to read 'Kenny', is written over a horizontal line.

Kenny K. Hsi, CIH
Technical Director

HYGIENE TECHNOLOGIES INTERNATIONAL, INC.

APPENDIX A



CLIENT: State of California
Board of Equalization
450 N Street
Sacramento, California 94279

**TABLE 20903001-1010
AIRBORNE TOTAL FUNGI RESULTS
ELEVATOR LOBBY AREAS
SACRAMENTO, CALIFORNIA
MARCH 30, 2009**

Page 1

Results reported in spores per cubic meter of air (spores/M³)

SAMPLE NUMBER	20903001-TM601OUTLS	20903001-TM602LS	20903001-TM603LS	20903001-TM604LS
SAMPLING LOCATION/ACTIVITIES	Outdoors; about 20 feet east of building; approximately five feet above ground/Normal outdoor activities	21 st Floor; Elevator Lobby; about center; approximately five feet above floor/Normal office activities	18 th Floor; Elevator Lobby; about center; approximately five feet above floor/Normal office activities	16 th Floor; Elevator Lobby; about center; approximately five feet above floor/Normal office activities
START/STOP	9:53:00/9:58:00	10:03:00/10:08:00	10:11:00/10:16:00	10:18:00/10:23:00
SAMPLE TIME	5 minutes	5 minutes	5 minutes	5 minutes
Alternaria	P			
Ascospores	P			
Aureobasidium				
Basidiospores	470	52	52	P
Bipolaris/Drechslera group				
Botrytis				
Chaetomium	52			
Cladosporium	880	52	100	52
Curvularia				
Epicoccum				
Fusarium				
Myrothecium				
Nigrospora				
Oidium	P			
Penicillium/Aspergillus types	210	100	100	52
Pithomyces				
Rusts	52	P		52
Scopulariopsis				
Smuts (Periconia, Myxomycetes)	620	52	52	
Stachybotrys				
Stemphylium		52		
Torula	52			
Ulocladium				
Unidentified mitosporic fungi	210	P	100	
Background particulates*	Moderate	Moderate	Moderate	Light
TOTAL**	2,500	310	400	160

P = Spores present

* Background particulates is an indication of the amount of non-biological particulate matter present on the media and is graded (from least to greatest) as very light, light, moderate, heavy and very heavy.

** Note that all reported counts have been rounded to no more than two significant figures based on the sampling and analytical methods used, and therefore the total count may not equal the sum of the individual counts in a column.

HYGIENE TECHNOLOGIES INTERNATIONAL, INC.

APPENDIX A



CLIENT: State of California
Board of Equalization
450 N Street
Sacramento, California 94279

**TABLE 20903001-1010
AIRBORNE TOTAL FUNGI RESULTS
ELEVATOR LOBBY AREAS
SACRAMENTO, CALIFORNIA
MARCH 30, 2009**

Page 2

Results reported in spores per cubic meter of air (spores/M³)

SAMPLE NUMBER	20903001-TM605LS	20903001-TM606LS	20903001-TM607LS	20903001-TM608LS
SAMPLING LOCATION/ACTIVITIES	15 th Floor; Elevator Lobby; about center; approximately five feet above floor/Normal office activities	14 th Floor; Elevator Lobby; about center; approximately five feet above floor/Normal office activities	10 th Floor; Elevator Lobby; about center; approximately five feet above floor/Normal office activities	7 th Floor; Elevator Lobby; about center; approximately five feet above floor/Normal office activities
START/STOP	10:25:00/10:30:00	10:32:00/11:37:00	10:44:00/10:49:00	10:50:00/10:55:00
SAMPLE TIME	5 minutes	5 minutes	5 minutes	5 minutes
Alternaria				
Ascospores		P		
Aureobasidium				
Basidiospores	P	52		
Bipolaris/Drechslera group				
Botrytis				
Chaetomium				
Cladosporium	100	100	160	P
Curvularia				
Epicoccum		52		
Fusarium				
Myrothecium				
Nigrospora				
Penicillium/Aspergillus types	100	100	52	210
Pithomyces			P	
Rusts				P
Scopulariopsis				
Smuts (Periconia, Myxomycetes)		52	P	
Stachybotrys				
Stemphylium				
Torula		52	52	
Ulocladium				
Unidentified mitosporic fungi	52	52	100	52
Background particulates*	Moderate	Moderate	Moderate	Moderate
TOTAL**	250	460	360	260

P = Spores present

* Background particulates is an indication of the amount of non-biological particulate matter present on the media and is graded (from least to greatest) as very light, light, moderate, heavy and very heavy.

** Note that all reported counts have been rounded to no more than two significant figures based on the sampling and analytical methods used, and therefore the total count may not equal the sum of the individual counts in a column.

HYGIENE TECHNOLOGIES INTERNATIONAL, INC.

APPENDIX A



CLIENT: State of California
Board of Equalization
450 N Street
Sacramento, California 94279

**TABLE 20903001-1010
AIRBORNE TOTAL FUNGI RESULTS
ELEVATOR LOBBY AREAS
SACRAMENTO, CALIFORNIA
MARCH 30, 2009**

Page 3

Results reported in spores per cubic meter of air (spores/M³)

SAMPLE NUMBER	20903001-TM609LS	20903001-TM610LS	20903001-TM611LS	20903001-TM612OUTLS
SAMPLING LOCATION/ACTIVITIES	5 th Floor; Elevator Lobby; about center; approximately five feet above floor/Normal office activities	3 rd Floor; Elevator Lobby; about center; approximately five feet above floor/Normal office activities	1 st Floor; Low Rise; Elevator Lobby; about center; approximately five feet above floor/Normal office activities	Outdoors; about 10 feet north of building; approximately five feet above ground/Normal outdoor activities
START/STOP	10:56:00/11:01:00	11:02:00/11:07:00	11:09:00/11:14:00	11:16:00/11:21:00
SAMPLE TIME	5 minutes	5 minutes	5 minutes	5 minutes
Alternaria				
Ascospores			100	
Aureobasidium				
Basidiospores	P	P	100	420
Bipolaris/Drechslera group				
Botrytis				
Chaetomium				
Cladosporium	P	52	620	1,100
Curvularia				
Epicoccum				
Fusarium				
Myrothecium				
Nigrospora				
Oidium				P
Penicillium/Aspergillus types	52	P	100	160
Pithomyces				
Rusts		52	P	
Scopulariopsis				
Smuts (Periconia, Myxomycetes)				52
Stachybotrys				
Stemphylium				
Torula	P		P	P
Ulocladium				P
Unidentified mitosporic fungi	160	100	100	160
Background particulates*	Light	Moderate	Moderate	Moderate
TOTAL**	210	200	1,000	1,900

P = Spores present

* Background particulates is an indication of the amount of non-biological particulate matter present on the media and is graded (from least to greatest) as very light, light, moderate, heavy and very heavy.

** Note that all reported counts have been rounded to no more than two significant figures based on the sampling and analytical methods used, and therefore the total count may not equal the sum of the individual counts in a column.



FINAL REPORT: Total Fungal Spore Trap Count

PROJECT NUMBER: 20903001

LABORATORY ID NUMBER: 0903045

Hygiene Technologies International, Inc.

Received Date: March 31, 2009

Attention: Wes Frey

Report Date: April 01, 2009

3127 Bowen Island St.

West Sacramento, CA 95691

Customer Sample Number: - TM601OUTLS Method: M101.1 Date Of Analysis: 01-Apr-09 Detection Limit: 52 Spores/M³
Background: Moderate particulates Sample Intact: Yes

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Alternaria</i>		P	
<i>Ascospores</i>		P	
<i>Basidiospores</i>	9	470	
<i>Chaetomium</i>	1	52	
<i>Cladosporium</i>	17	880	
<i>Oidium</i>		P	
<i>Penicillium/Aspergillus types</i>	4	210	
<i>Pollen</i>	4	210	
<i>Rusts</i>	1	52	
<i>Smuts/Myxomycetes</i>	12	620	
<i>Torula</i>	1	52	
<i>Unidentified mitosporic fungi</i>	4	210	
TOTAL	49	2500	

Sample results have not been corrected based on a blank sample

P = Spores Present

< (less than) = measurement below the reporting limit

Rounding: Note that all reported counts have been rounded to two significant figures based on the sampling and analytical methods used. BioHygiene Labs rounds such that if the last significant digit is an even number, then the result is rounded down to that digit; if the last significant digit is an odd number, then it is rounded up to the nearest even number. Thus the TOTAL may not equal the sum of the individual counts per column. TOTAL rows do not include pollen.

Background is graded as Very Light (0 - 10%), Light (>10 - 30%), Moderate (>30 - 70%), Heavy (>70 - 90%), and Very Heavy (>90%) Particulates as a percentage of the trace area.

APPROVED: _____

DATE: _____

Name _____

Title: _____

Results reported relate only to the sample items tested. This test report shall not be reproduced (except in full), corrected or added to without written approval from BioHygiene Laboratories, Inc.



FINAL REPORT: Total Fungal Spore Trap Count

PROJECT NUMBER: 20903001
Hygiene Technologies International, Inc.
Attention: Wes Frey
3127 Bowen Island St.
West Sacramento, CA 95691

LABORATORY ID NUMBER: 0903045
Received Date: March 31, 2009
Report Date: April 01, 2009

Customer Sample Number: -TM602LS **Method: M101.1** **Date Of Analysis: 01-Apr-09** **Detection Limit: 52 Spores/M³**
Background: Moderate particulates **Sample Intact: Yes**

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Basidiospores</i>	1	52	
<i>Cladosporium</i>	1	52	
<i>Penicillium/Aspergillus types</i>	2	100	
<i>Pollen</i>	7	360	
<i>Rusts</i>		P	
<i>Smuts/Myxomycetes</i>	1	52	
<i>Stemphylium</i>	1	52	
<i>Unidentified mitosporic fungi</i>		P	
TOTAL	6	310	

Customer Sample Number: -TM603LS **Method: M101.1** **Date Of Analysis: 01-Apr-09** **Detection Limit: 52 Spores/M³**
Background: Moderate particulates **Sample Intact: Yes**

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Basidiospores</i>	1	52	
<i>Cladosporium</i>	2	100	
<i>Penicillium/Aspergillus types</i>	2	100	
<i>Pollen</i>	4	210	
<i>Smuts/Myxomycetes</i>	1	52	
<i>Unidentified mitosporic fungi</i>	2	100	
TOTAL	8	400	

Sample results have not been corrected based on a blank sample

P = Spores Present

< (less than) = measurement below the reporting limit

Rounding: Note that all reported counts have been rounded to two significant figures based on the sampling and analytical methods used. BioHygiene Labs rounds such that if the last significant digit is an even number, then the result is rounded down to that digit; if the last significant digit is an odd number, then it is rounded up to the nearest even number. Thus the TOTAL may not equal the sum of the individual counts per column. TOTAL rows do not include pollen.

Background is graded as Very Light (0 - 10%), Light (>10 - 30%), Moderate (>30 - 70%), Heavy (>70 - 90%), and Very Heavy (>90%) Particulates as a percentage of the trace area.

APPROVED: **DATE:** 04.01.09
Name Lucas Walker **Title:** Quality Manager

Results reported relate only to the sample items tested. This test report shall not be reproduced (except in full), corrected or added to without written approval from BioHygiene Laboratories, Inc.



FINAL REPORT: Total Fungal Spore Trap Count

PROJECT NUMBER: 20903001

LABORATORY ID NUMBER: 0903045

Hygiene Technologies International, Inc.

Received Date: March 31, 2009

Attention: Wes Frey

Report Date: April 01, 2009

3127 Bowen Island St.

West Sacramento, CA 95691

Customer Sample Number: -TM604LS

Method: M101.1

Date Of Analysis: 01-Apr-09

Detection Limit: 52 Spores/M³

Background: Light particulates

Sample Intact: Yes

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Basidiospores</i>		P	
<i>Cladosporium</i>	1	52	
<i>Penicillium/Aspergillus types</i>	1	52	
<i>Pollen</i>	1	52	
<i>Rusts</i>	1	52	
TOTAL	3	160	

Customer Sample Number: -TM605LS

Method: M101.1

Date Of Analysis: 01-Apr-09

Detection Limit: 52 Spores/M³

Background: Moderate particulates

Sample Intact: Yes

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Basidiospores</i>		P	
<i>Cladosporium</i>	2	100	
<i>Penicillium/Aspergillus types</i>	2	100	
<i>Pollen</i>		P	
<i>Unidentified mitosporic fungi</i>	1	52	
TOTAL	5	250	

Sample results have not been corrected based on a blank sample

P = Spores Present

< (less than) = measurement below the reporting limit

Rounding: Note that all reported counts have been rounded to two significant figures based on the sampling and analytical methods used. BioHygiene Labs rounds such that if the last significant digit is an even number, then the result is rounded down to that digit; if the last significant digit is an odd number, then it is rounded up to the nearest even number. Thus the TOTAL may not equal the sum of the individual counts per column. TOTAL rows do not include pollen.

Background is graded as Very Light (0 - 10%), Light (>10 - 30%), Moderate (>30 - 70%), Heavy (>70 - 90%), and Very Heavy (>90%) Particulates as a percentage of the trace area.

APPROVED: _____

DATE: _____

Name _____

Title: _____

Results reported relate only to the sample items tested. This test report shall not be reproduced (except in full), corrected or added to without written approval from BioHygiene Laboratories, Inc.



FINAL REPORT: Total Fungal Spore Trap Count

PROJECT NUMBER: 20903001

LABORATORY ID NUMBER: 0903045

Hygiene Technologies International, Inc.

Received Date: March 31, 2009

Attention: Wes Frey

Report Date: April 01, 2009

3127 Bowen Island St.

West Sacramento, CA 95691

Customer Sample Number: -TM606LS

Method: M101.1

Date Of Analysis: 01-Apr-09

Detection Limit: 52 Spores/M³

Background: Moderate particulates

Sample Intact: Yes

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Ascospores</i>		P	
<i>Basidiospores</i>	1	52	
<i>Cladosporium</i>	2	100	
<i>Epicoccum</i>	1	52	
<i>Penicillium/Aspergillus types</i>	2	100	
<i>Pollen</i>	5	260	
<i>Smuts/Myxomycetes</i>	1	52	
<i>Torula</i>	1	52	
<i>Unidentified mitosporic fungi</i>	1	52	
TOTAL	9	460	

Customer Sample Number: -TM607LS

Method: M101.1

Date Of Analysis: 01-Apr-09

Detection Limit: 52 Spores/M³

Background: Moderate particulates

Sample Intact: Yes

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Cladosporium</i>	3	160	
<i>Penicillium/Aspergillus types</i>	1	52	
<i>Pithomyces</i>		P	
<i>Pollen</i>		P	
<i>Smuts/Myxomycetes</i>		P	
<i>Torula</i>	1	52	
<i>Unidentified mitosporic fungi</i>	2	100	
TOTAL	7	360	

Sample results have not been corrected based on a blank sample

P = Spores Present

< (less than) = measurement below the reporting limit

Rounding: Note that all reported counts have been rounded to two significant figures based on the sampling and analytical methods used. BioHygiene Labs rounds such that if the last significant digit is an even number, then the result is rounded down to that digit; if the last significant digit is an odd number, then it is rounded up to the nearest even number. Thus the TOTAL may not equal the sum of the individual counts per column. TOTAL rows do not include pollen.

Background is graded as Very Light (0 - 10%), Light (>10 - 30%), Moderate (>30 - 70%), Heavy (>70 - 90%), and Very Heavy (>90%) Particulates as a percentage of the trace area.

APPROVED: _____

DATE: 04-01-09

Name _____

Lucas Walker

Title: _____

Quality Manager

Results reported relate only to the sample items tested. This test report shall not be reproduced (except in full), corrected or added to without written approval from BioHygiene Laboratories, Inc.



FINAL REPORT: Total Fungal Spore Trap Count

PROJECT NUMBER: 20903001

LABORATORY ID NUMBER: 0903045

Hygiene Technologies International, Inc.

Received Date: March 31, 2009

Attention: Wes Frey

Report Date: April 01, 2009

3127 Bowen Island St.

West Sacramento, CA 95691

Customer Sample Number: -TM608LS

Method: M101.1

Date Of Analysis: 01-Apr-09

Detection Limit: 52 Spores/M³

Background: Moderate particulates

Sample Intact: Yes

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Cladosporium</i>		P	
<i>Penicillium/Aspergillus types</i>	4	210	
<i>Pollen</i>	1	52	
<i>Rusts</i>		P	
<i>Unidentified mitosporic fungi</i>	1	52	
TOTAL	5	260	

Customer Sample Number: -TM609LS

Method: M101.1

Date Of Analysis: 01-Apr-09

Detection Limit: 52 Spores/M³

Background: Light particulates

Sample Intact: Yes

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Basidiospores</i>		P	
<i>Cladosporium</i>		P	
<i>Penicillium/Aspergillus types</i>	1	52	
<i>Torula</i>		P	
<i>Unidentified mitosporic fungi</i>	3	160	
TOTAL	4	210	

Sample results have not been corrected based on a blank sample

P = Spores Present

< (less than) = measurement below the reporting limit

Rounding: Note that all reported counts have been rounded to two significant figures based on the sampling and analytical methods used. BioHygiene Labs rounds such that if the last significant digit is an even number, then the result is rounded down to that digit; if the last significant digit is an odd number, then it is rounded up to the nearest even number. Thus the TOTAL may not equal the sum of the individual counts per column. TOTAL rows do not include pollen.

Background is graded as Very Light (0 - 10%), Light (>10 - 30%), Moderate (>30 - 70%), Heavy (>70 - 90%), and Very Heavy (>90%) Particulates as a percentage of the trace area.

APPROVED:

DATE:

04.01.09

Name

Lucas Wallin

Title:

Quality Manager

Results reported relate only to the sample items tested. This test report shall not be reproduced (except in full), corrected or added to without written approval from BioHygiene Laboratories, Inc.

FINAL REPORT: Total Fungal Spore Trap Count

PROJECT NUMBER: 20903001
Hygiene Technologies International, Inc.
 Attention: Wes Frey
 3127 Bowen Island St.
 West Sacramento, CA 95691

LABORATORY ID NUMBER: 0903045
Received Date: March 31, 2009
Report Date: April 01, 2009

Customer Sample Number: -TM610LS **Method:** M101.1 **Date Of Analysis:** 01-Apr-09 **Detection Limit:** 52 Spores/M³
Background: Moderate particulates **Sample Intact:** Yes

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Basidiospores</i>		P	
<i>Cladosporium</i>	1	52	
<i>Penicillium/Aspergillus types</i>		P	
<i>Pollen</i>		P	
<i>Rusts</i>	1	52	
<i>Unidentified mitosporic fungi</i>	2	100	
TOTAL	4	200	

Customer Sample Number: -TM611LS **Method:** M101.1 **Date Of Analysis:** 01-Apr-09 **Detection Limit:** 52 Spores/M³
Background: Moderate particulates **Sample Intact:** Yes

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Ascospores</i>	2	100	
<i>Basidiospores</i>	2	100	
<i>Cladosporium</i>	12	620	
<i>Penicillium/Aspergillus types</i>	2	100	
<i>Pollen</i>	1	52	
<i>Rusts</i>		P	
<i>Torula</i>		P	
<i>Unidentified mitosporic fungi</i>	2	100	
TOTAL	20	1000	


Sample results have not been corrected based on a blank sample

P = Spores Present

< (less than) = measurement below the reporting limit

Rounding: Note that all reported counts have been rounded to two significant figures based on the sampling and analytical methods used. BioHygiene Labs rounds such that if the last significant digit is an even number, then the result is rounded down to that digit; if the last significant digit is an odd number, then it is rounded up to the nearest even number. Thus the TOTAL may not equal the sum of the individual counts per column. TOTAL rows do not include pollen.

Background is graded as Very Light (0 - 10%), Light (>10 - 30%), Moderate (>30 - 70%), Heavy (>70 - 90%), and Very Heavy (>90%) Particulates as a percentage of the trace area.

APPROVED:  **DATE:** 04-01-09
Name Lucas Walker **Title:** Quality Manager

Results reported relate only to the sample items tested. This test report shall not be reproduced (except in full), corrected or added to without written approval from BioHygiene Laboratories, Inc.

FINAL REPORT: Total Fungal Spore Trap Count
PROJECT NUMBER: 20903001
LABORATORY ID NUMBER: 0903045
Hygiene Technologies International, Inc.
Received Date: March 31, 2009

Attention: Wes Frey

Report Date: April 01, 2009

3127 Bowen Island St.

West Sacramento, CA 95691

**Customer Sample Number: -
TM612OUTLS**
Method: M101.1
Date Of Analysis: 01-Apr-09
Detection Limit: 52 Spores/M³
Background: Moderate particulates
Sample Intact: Yes

Genus (species)	Raw Count	Total Spores / M ³	Comment
<i>Basidiospores</i>	8	420	
<i>Cladosporium</i>	21	1100	
<i>Oidium</i>		P	
<i>Penicillium/Aspergillus types</i>	3	160	
<i>Pollen</i>	1	52	
<i>Smuts/Myxomycetes</i>	1	52	
<i>Torula</i>		P	
<i>Ulocladium</i>		P	
<i>Unidentified mitosporic fungi</i>	3	160	
TOTAL	36	1900	


Sample results have not been corrected based on a blank sample

P = Spores Present

< (less than) = measurement below the reporting limit

Rounding: Note that all reported counts have been rounded to two significant figures based on the sampling and analytical methods used. BioHygiene Labs rounds such that if the last significant digit is an even number, then the result is rounded down to that digit; if the last significant digit is an odd number, then it is rounded up to the nearest even number. Thus the TOTAL may not equal the sum of the individual counts per column. TOTAL rows do not include pollen.

Background is graded as Very Light (0 - 10%), Light (>10 - 30%), Moderate (>30 - 70%), Heavy (>70 - 90%), and Very Heavy (>90%) Particulates as a percentage of the trace area.

APPROVED:

DATE:

04.01.09

Name

Lucas Walker

Title:

Quality Manager

Results reported relate only to the sample items tested. This test report shall not be reproduced (except in full), corrected or added to without written approval from BioHygiene Laboratories, Inc.



Request For Analysis

Project Number/Purchase Order: 20903001 Date Submitted: 3/30/19

Project Contact: W. Frey Turnaround Required: Normal

Lab Destination: Biohygiene Labs Lab Contact: Rupa Arora

SAMPLE ID	VOLUME	MEDIA	ANALYSIS REQUESTED
20903001 TM6010LS	75L	Allergent	M101.1
20903001 TM602LS			
20903001 TM603LS			
20903001 TM604LS			
20903001 TM605LS			
20903001 TM606LS			
20903001 TM607LS			
20903001 TM608LS			
20903001 TM609LS			
20903001 TM610LS			
20903001 TM611LS			
20903001 TM6120LS			

APR 3-31-09

Special Instructions:

1. Sampled by: W. Frey on 3/30/19 @ 9:30 Received by: R. Gallegos 03-31-09 7:35A

2. Relinquished by: W. Frey 03-31-09 Received by: Rupa 03-31-09, 10:05AM (-TM6010LS -TM604LS)

3. Relinquished by: W. Frey on 3/30/19 @ 16:00 Received by: R. Gallegos 04-01-09 (-TM609LS to -TM6120LS)

4. Relinquished by: R. Gallegos 03-31-09 8:00A Please include signature, date, and time. R. Arora 04-01-09 (-TM6120LS to -TM6120LS) 09:19A

Lab Use Only: Completed on 03-31-09, Book 3230 p. 77 (-TM6100LS, -TM602LS), p. 79 (-TM603LS); 04-01-09, Book 3230, p. 79 (-TM604LS) RA

Completed on 04-01-09 Book 3241 p. 43 (-TM605LS, -TM606LS), p. 44 (-TM607LS, -TM608LS) RA

Completed on 04-01-09 Book 3239 p. 83 (-TM609LS, -TM610LS), p. 84 (-TM611LS, -TM6120LS) RA